

Architecture & Access (Aust) Pty Ltd ABN 45 159 663 582

P 1300 715 866 E info@archaccess.com.au www.architectureandaccess.com.au

# **Accessibility Statement**

Architecture & Access find the Aquafil FlexiFountain has been designed in line with the spirit and intent of the Disability Discrimination Act 1992 (cth). It provides a drinking fountain and bottle filling station with the following features to meet the needs of of a wide range of users including people with a disability.

## **Civiq Aquafil FlexiFountain** Product Code: AQ-FF1200B/BF, AQ-FF1500B/BF/BFF, AQ-FF2100B/BF/BFF

### Knee & Foot Clearance

Knee and foot clearance has been provided. It will accommodate most people using a manual wheelchair. Assessed against:

- AS1428.1: 2001 Requirements for washbasins (which perform a similar function)
- International Standards

#### Water Fountain Outlet

The accessible drinking fountain water-flow outlet has a projected water-flow height of approximately 900mm. It is provided at a height within the range required for accessibility. Assessed against:

- International Standards, in lieu of AS1428.2: 1992 Clause 27.3.2

#### Water Bottle Refill Outlet

Multiple water refill outlets are provided on the side of the unit at different heights of between 900mm and 1350mm above ground level. This is within the recommended range of accessibility. Assessed against:

- AS1428.2: 1992 Figure 21

#### Controls

Drinking fountain and water refill controls (buttons) are provided in an accessible location. They do not exceed 19.5N of force to operate. Assessed against:

- AS1428.2: 1992 Clause 27.3.3
- AS1428.1: 2009 Requirements for washbasins (which perform a similar function)

#### **Universal Design**

Unit is designed to accommodate for a front and side on approach. This enables operation by users with a preference for either their left or right hand equally, and provides multiple modes of use for a variety of people and their diverse needs.

#### **Compliance with Standards**

This product is in line with international standards, more recent Australian Standards and current anthropometric data of people seated in a manual wheelchair. Strict compliance with all the requirements of AS1428.2: 1992 is not considered appropriate now given that this standard is more than 30 years old.